



Product Service

Attestation of Conformity

No. N8A 112610 0003 Rev. 00

Holder of Certificate: **ATTACK, s.r.o.**
Dielenská Kružná 5020
038 61 Vrútky
SLOVAKIA

Product: **Heat pumps**
(DC Inverter Air to Water Heat Pump Unit)

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 64111210441801

Date, 2022-02-22

(Sam Yang)

Page 1 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 112610 0003 Rev. 00

Model(s):

Indoor unit:
 ATTACK Tepelné čerpadlo, Inverter, R32,
 Vzduch/Voda 15 kW/IA,
Outdoor unit:
 ATTACK Tepelné čerpadlo, Inverter, R32,
 Vzduch/Voda 15kW/OA,
Indoor unit:
 ATTACK Tepelné čerpadlo, Inverter, R32,
 Vzduch/Voda 19 kW/IA,
Outdoor unit:
 ATTACK Tepelné čerpadlo, Inverter, R32,
 Vzduch/Voda 19 kW/OA

Brand: **ATTACK**



Parameters:

Rated Voltage: 380-420V, 3N~
 Rated Frequency: 50Hz
 Supplementary heaters
 power input: 6400W
 Protection Class: Class I
 Degree of Protection: IPX4 for outdoor unit,
 IPX0 for indoor unit.
 Refrigerant: R32

Indoor unit	Outdoor unit	Rated power (cooling)	Rated power (heating)
ATTACK Tepelné čerpadlo, Inverter, R32, Vzduch/Voda 15 kW/IA	ATTACK Tepelné čerpadlo, Inverter, R32, Vzduch/Voda 15kW/OA	4600W	5500+6400W
ATTACK Tepelné čerpadlo, Inverter, R32, Vzduch/Voda 19 kW/IA	ATTACK Tepelné čerpadlo, Inverter, R32, Vzduch/Voda 19 kW/OA	5000W	6000+6400W

Page 2 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 112610 0003 Rev. 00

**Tested
according to:**

EN 60335-1:2012/A15:2021
EN 60335-2-40:2003/A13:2012
EN 62233:2008

Page 3 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.